

RESOLUTION NO. 93-05

=====

A RESOLUTION OF THE LODI CITY COUNCIL
AWARDING THE BID FOR THE PURCHASE OF VARIOUS SIZES OF
PADMOUNT TRANSFORMERS FOR THE ELECTRIC UTILITY DEPARTMENT

=====

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened on December 15, 1992 at 11:00 a.m. for the bid for the purchase of various sizes of padmount transformers for the Electric Utility Department, described in the specifications therefor approved by the City Council on November 4, 1992; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Exhibit A; and

WHEREAS, the City Manager recommends that award of the bid for be made to the two responsible bidders whose proposals and equipment met City specifications, specifications, and whose transformers yielded the lowest overall life-cycle costs in each rating category, to wit:

Westinghouse Electric Supply Co., Concord, CA

6 ea 37.5KVA Single-phase 240/120V	\$ 7,298.98
5 ea 75KVA Single-phase 240/120V	7,704.12
2 ea 167KVA Single-phase 240/120V	<u>6,314.15</u>
Subtotal	\$21,317.25

Pauwels Transformers, Washington, MO

1 ea 75KVA Three-phase 208Y/120V	\$ 3,111.82
1 ea 300KVA Three-phase 208Y/120V	5,702.13
1 ea 500KVA Three-phase 208Y/120V	7,691.20
1 ea 150KVA Three-phase 480Y/277V	3,765.86
2 ea 225KVA Three-phase 480Y/277V	10,499.16
1 ea 1500KVA Three-phase 480Y/277V	<u>17,211.99</u>
Subtotal	\$47,982.16

Total, all sizes \$69,299.41

NOW, THEREFORE, BE IT RESOLVED by the Lodi City Council that award of bid for the above-described padmount transformers be and the same is hereby awarded to the two above-described responsible bidders, in the total amount of \$69,299.41.

Dated: January 6, 1993


=====

I hereby certify that Resolution No. 93-05 was passed and adopted by the City Council of the City of Lodi in a regular meeting held January 6, 1993 by the following vote:

Ayes: Council Members - Davenport, Mann, Sieglock, Snider
and Pennino (Mayor)

Noes: Council Members - None

Absent: Council Members - None


Alice M. Reimche
City Clerk

BID EVALUATION - POLEMOUNT TRANSFORMERS

BIDS OPENED DECEMBER 15, 1992

(AMOUNTS SHOWN ARE BID AMOUNT / LIFE-CYCLE COST)

QTY/RATING/DESCRIPTION -----	B I D D E R		
	WESTINGHOUSE -----	KUHLMAN -----	GEN. ELECT. ----(1)----
<u>Circuit-Protected</u>			
3 ea 25KVA 120/240V	\$ 1,907.17/ 4,691.17	\$ 1,810.20/ 4,876.20	\$ 2,285.38/ 4,679.38
12 ea 37.5KVA 120/240V	\$ 9,115.65/ 35,347.65(2)	\$ 9,813.87/ 25,725.87	\$11,611.14/ 25,315.14
12 ea 50KVA 120/240V	\$10,525.02/ 30,157.02	\$10,033.68/ 34,153.68	\$13,770.45/ 30,810.45
<u>Conventional</u>			
6 ea 37.5KVA 120/240V	\$ 3,251.89/ 10,871.89	\$ 4,176.39/ 11,760.39	\$ 5,314.23/ 11,842.23
9 ea 50KVA 120/240V	\$ 7,020.99/ 20,916.99	\$ 6,448.84/ 22,288.84	\$ 9,697.50/ 21,703.50

Footnotes:

- (1) General Electric's proposal included terms and conditions which, among other things, (a) modified the method by which actual transformer losses would be calculated for penalty purposes, a modification in GE's favor, (b) placed risk of loss or damage of the transformers during shipment on the City of Lodi (bid specifications require bidder assume that risk), and (c) dictated that matters relating to any order placed pursuant to the bid, including any legal action the City may be required to take, be governed by laws of the State of New York.

A subsequent retraction of its standard terms and conditions which were in conflict with the City's bid specifications was submitted after the bid opening by a GE representative who may not be authorized under the terms and conditions to make such a retraction.

General Electric's bid must therefore be deemed non-responsive and subject to disqualification.

- (2) Westinghouse Electric's 37.5KVA unit height of 47" exceeds specified equipment height maximum of 45".